

**Local Limits for Oregon Approved Pretreatment Programs**

Local Limits for Oregon Approved Pretreatment Programs	Albany	Bend	Canby	CCSD#1	CWS	Corvallis	Grants Pass	Gresham	Klamath Fall	McMinnville	Medford	MWMC	Newberg**	Portland	RUSA	Salem	St. Helens**	The Dalles	Tri-city	Troutdale	Wilsonville	Woodburn	Vancouver, V
Arsenic (AS)	1.0	0.76	2.58	0.16	0.34	0.658	1.36	0.48	1.78	0.3	0.19	0.3		0.20	0.23	0.31		0.11	0.35		0.09	0.040	0.22
Cadmium (Cd)	0.6	0.35	1.47	0.24	0.19	0.400	0.31	0.50	0.44	0.2	0.15	0.3		0.70	0.17	0.15		0.09	0.24	0.1	0.05	1.720	0.14
Chromium (Cr)	2.8	3.21	12.82	2.77	10.22	27.9	2.77	1.58	NA	5.7	NA	2.0		5.00		4.91		NA	2.77			1.520	7.22
Copper (Cu)	3.4	14.5	0.63	3.84	2.71	3.00	2.52	2.0	1.1	2.1	2.21	1.5		3.70	5.13	3.19		2.15	3.38	0.9	0.54	1.240	3.67
Cyanide (CN)	1.2	7.43	5.50	1.20	1.38	1.83	2.24	1.0	BMP	0.5	0.22	2.6		1.20	0.27	1.84		0.33	1.20		0.50	1.200	0.47
Lead (pb)	0.7	1.0	3.03	0.81	1.12	1.39	2.27	1.0	0.57	0.8	0.79	1.4		0.70	1.25	0.54		0.09	1.36		0.58	1.160	0.44
Mercury (Hg)	0.08	0.023	0.37	0.0035	0.008	0.080	0.08	0.1	0.0022	0.04	0.03	0.05		0.010	0.018	0.006		0.027	0.0035	0.04	0.015	0.0020	0.008
Molybdenum (Mo)	4.0	2.03			1.06	1.01	1.5	6.58	1.8	0.6	NA	NA		1.40		4.32				0.4			0.42
Nickel (Ni)	1.6	9.56	10.17	2.45	2.31	3.03	3.98	3	2.95	1.8	3.09	1.7		2.80	1.97	3.14		0.79	3.35		0.61	1.930	0.90
Selenium (Se)	3.0	0.91			0.97	1.11	1.38	4.48	5.97	0.7	NA	NA		0.60		0.61		0.50		0.4			0.31
Silver (Ag)	1.1	2.32	0.75	0.56	0.09	0.719	1.00	0.47	0.031	0.2	0.67	0.8		0.40	0.16	0.25		1.18	0.43	0.1	0.11	0.2400	1.13
Zinc (Zi)	2.6	50.5	10.41	2.61	3.28	4.6	2.61	4.0	2.31	2.8	3.40	1.6		3.70	12.03	3.36		4.5	2.61	3.9	1.30	2.610	1.64
pH*	6.0-10.0		6.0-10.0	5.5-11.5	6.0-11.0					6.0-11.0		5.5-12.0		5.0-11.5		6.5-10.0		6.0-9.0	5.5-11.5	6.0-9.0	5.5-10.0	5.5-10.0	5.5-10
Oil and Grease (Non-Polar,HEM)	300			100	BMP			100				100		110	25.00			100	100.00	100.0		100.0	50
Phenol												3.5		NA									
Pentachlorophenol														0.04									
Chlorobenzene														0.20									
Chloroform														0.20									
Trichloroethylene														0.20									
1,2-dichloroethane														0.50									
2,4-dinitrotoluene														0.13									
Nitrobenzene														2.00									
Chlordane														0.03									
Acrylonitrile														1.00									
TTOs				2.13																2.13			
Oil and Grease (Polar)				300																300.0			
Oil and Grease (Total)				100						100	500				100.0					100.0			
Temprature to Coll. System (°F)										140								150		76.5***			
Temprature to plant (°F)										104								104					
Thallium							0.03																
Benzene							0.20																
1,4-Dichlorobenzene							1.53																
Chloroform							1.10																
Tetrachloroethene							0.03																

\* In standard pH units

\*\* No Local Limit

TSS

250

BOD

250

\*\*\*Thermal load policy for greater than 76.5F; requires monitoring and reporting.